



NOTES

1. 48" STRUCTURE SHALL BE USED WHENEVER THE CLEANOUT FALLS INTO PAVEMENT AREAS.
- ② MANHOLE COVER SHALL CONFORM TO MN/DOT S.P. 4020 J.
- ③ REFER TO PLANS AND S.D.P. 1-11 FOR CASTING REQUIRED. CASTING SHALL BE BOLTED TO CONCRETE IN FIELD APPLICATIONS.
- ④ ADJUSTING RINGS SHALL BE PER S.D.P. 1-12, AND BE FULLY MORTARED.
- ⑤ MANHOLE COVER IS TO BE A MINIMUM OF 4" AND A MAXIMUM OF 6" BELOW THE FINISHED PAVEMENT GRADE.

DEPARTMENT OF PUBLIC WORKS CITY OF ROCHESTER, MINNESOTA			
STRUCTURE TYPE 6 (CLEANOUT)			
<i>Donald Nelson</i> ASST. CITY ENGINEER		<i>Keith W. Finner</i> DIRECTOR	
SHT 1 OF 1 SHTS	DATE REVISED 6/15/07	PLATE NO. 1-06	REV. B